

JHARKHAND HIGH COURT: RANCHI

NOTICE INVITING QUOTATION

Dated: 24th June, 2013

DG Sets are required to be installed in the judgements given below in the manner provided in the chart shown against each judgement. The authorized suppliers / agencies who are interested to supply and install DG Sets of any reputed makes with ISI mark are requested to submit there (DGS&D & General Rate) Quotations to the undersigned in a sealed cover which must include the rates of item, charges of civil work /installation at site, Earthing, cabling, changeover switch, platform and labour charges etc. by 04.07.2013. The suppliers / agencies are requested to enclose an authority letter along with Quotation. The general terms & conditions with specification of the items are mentioned below.

DG sets requirement & tentative specification

Sl. No.	Name of the site	Capacity	No. of phases	Type of Operation	Other Technical specifications / norms if any
1.	West Singbhum, Chaibasa	25 KVA or more.	Single Phase Or Three Phases (As per the availability of manufacturers)	Manually Or Automatic operated SILENT DG Set.	<ul style="list-style-type: none">• Dry Type Air cleaner• Exhaust Silencer• Expansion bellow• Lube oil Cooler• Lube oil filter• Fuel Filters (Pre and Micro)• 12 volt electric starter• Battery charging alternator• Protection Systems for: (Low lube oil pressure and High water temperature)• Well equipped with all display parameters with regard to electrical and mechanical safety. Better information System.• Higher capacity of fuel tank
2.	Gumla	25 KVA or more.			
3.	Lohardaga	25 KVA or more.			
4.	Latehar	25 KVA or more.			
5.	Palamau	50 KVA or more.			
6.	Garhwa	25 KVA or more.			
7.	Giridih	50 KVA or more.			
8.	Seraikella-Kharsawan	25 KVA or more			

GENERAL TERMS AND CONDITIONS WITH REGRD TO THE TENDER

1. Tenders have to submit in sealed quotation for the supply of (25 KVA & more) and 50 (KVA or more) any reputed make diesel generator and accessories, including civil work for concrete foundation to mount GENSET, installation, cable laying and electrical work including supply of AMF panels & changeover switch.
2. The sealed tenders have to be submitted to **“The Central Project Coordinator, E-Committee, Jharkhand High Court, Office of CPC, Above Record Room, 2nd Floor, Ranchi, 834002 on or before 4th July, 2013 (upto 17.00 hrs).**
3. All the materials for foundation, shall be supplied by the supplier including metallic items like bolts, anchor plates, steel templates etc.
4. All necessary arrangements for erection of DG sets are to be made by the supplier including supply of all safety appliances and tools to workmen.
5. The whole work to be completed within 15 days from the date of work order issued.
6. After completion of job, supplier shall carry out the measurements of power generated and shall furnish the test report to the concerned Nodal Officers of the site.
7. Transportation including loading / unloading to the installation site will be done by the supplier. The delivery sites of DG Sets are namely; Chaibasa, Gumla, Lohardaga, Latehar, Palamau, Garhwa, Giridih and Seraikella-Kharsawan Civil Courts.
8. The rates quoted against the tender shall be valid for a period 120 days.
9. The quotation must be enclosed with the following documents,
 - (a) Details of the R.C.C foundation,
 - (b) Quality Assurance Plan of manufacturers for DG Sets,
 - (c) Catalogue of DG Set,
 - (d) Upto date sales tax / VAT registration etc.
 - (e) Warranty and service conditions after warranty.

Sd/-
(Manoranjan Kavi)
C.P.C, E-Committee,
Jharkhand High Court, Ranchi.